



NOTE:
 1) PIPE MATERIAL SHALL BE SAME AS MAIN.

ITEM	MATERIAL	ITEM	MATERIAL
(1)	WATER MAIN W/ FLG'D OUTLET.	(5)	8" CL 100, SDR41 WHITE
(2)	90° BEND, FLG'D	(6)	PIPE SPOOL PIECE, FL x FL.
(3)	THRUST BLOCK, PER VWD DWG W-15.	(7)	PIPE RISER, FL x FL.
(4)	GATE VALVE, FLG'D		

REVISIONS			VALLECITOS WATER DISTRICT STANDARD DRAWING	DATE: JULY 2015
DESCRIPTION	APPROVED	DATE		BY:
REMOVED VALVE RISER STEM		9-9-16	3" AND LARGER AIR RELEASE ASSEMBLY	Drawing No.
				W-24