



NOTE:

1) PIPE MATERIAL SHALL BE SAME AS MAIN.

ITEM	MATERIAL	ITEM	MATERIAL
①	WATER MAIN W/ FLG'D OUTLET.	⑤	RISER, FL x FL.
②	GATE VALVE, FLG'D.	⑥	90° ELBOW W/ MIP THREADS & CAP
③	PIPE SPOOL PIECE, FL x FL.	⑦	THRUST BLOCK, PER VWD DWG W-15.
④	90 DEGREE FL. ELBOW		

REVISIONS			VALLECITOS WATER DISTRICT STANDARD DRAWING	DATE: JULY 2015
DESCRIPTION	APPROVED	DATE		BY:
REMOVED VALVE RISER STEM		9-9-16		Drawing No.
				W-23

4" AND LARGER BLOW-OFF