



SAND/ D.G. TO BE PLACED IN 6" LAYERS THROUGHOUT PIPE ZONE & THOROUGHLY COMPACTED BEFORE ANY ADDITIONAL BACKFILL SHALL BE PLACED.

NOTES:

- 1) LOCATION TAPE TO BE 12" ABOVE PIPE REFER TO MATERIAL LIST.

REVISIONS			VALLECITOS WATER DISTRICT STANDARD DRAWING	DATE: JAN. 04
DESCRIPTION	APPROVED	DATE		BY:
			TRENCH COMPACTION AND BACKFILL	Drawing No.
				W-17