



**NOTE:**  
 THE SEWER MAIN SHALL BE LAID FOR THE FULL LENGTH AND DEPTH SHOWN ON THE PLANS AND PROFILE TO THE POINT MARKED DEAD END (D.E.)

**NOTE:**  
 THE TRENCH FOR A DEAD END SHALL BE EXCAVATED ONLY TO SUBGRADE, WHICH IS THE BOTTOM OF THE SLOPING PIPE AND FITTINGS. SHOULD THE EXCAVATION FOR ANY REASON BE CARRIED BELOW SUCH A GRADE, IT SHALL BE REFILLED TO GRADE WITH TYPE 'A' CRUSHED ROCK WHICH SHALL BE TAMPED FIRM AND UNYIELDING. SHOULD A FIRM AND UNYIELDING FOUNDATION BE UNOBTAINABLE BY THIS METHOD, A PARTIAL CONCRETE CRADLE SHALL BE EMPLOYED.

REVISIONS			VALLECITOS WATER DISTRICT STANDARD DRAWING	DATE: JAN. 04
DESCRIPTION	APPROVED	DATE		BY:
THREADED PLUG		6-13-11	<b>DEAD END CLEAN-OUT</b>	Drawing No. <b>S-8</b>